



ARM-EVAC[®] 50

Benchtop Plenum/Arm Extractor

MANUAL NO. 8881-0980 REV. C

TABLE OF CONTENTS

Safety..... 1

Introduction 2

Specifications..... 2

Features..... 3

Set up 4

Maintenance 5

Troubleshooting..... 6

Filter Replacement & Spare Parts 6

Warranty 7

WARNING
Read the safety & setup information sections in this manual before installing and using your fume extraction system.

Safety

PACE Fume Extraction systems are designed to reduce the level of harmful contaminants from the work environment and to assist in achieving the recommended health and safety requirements for local exhaust ventilation and contaminant removal. Be sure to follow all safety guidelines contained here and in other relevant safety literature (i.e., Material Safety Data Sheets) provided with the substances and equipment producing the fumes to be extracted.

Disclaimer

PACE hereby disclaims all responsibility for any personal injury, property damage, fine, citation or penalty imposed by any government or private entity which results from any use, misuse or misapplication of this product, failure of the user to regularly maintain the product according to the recommended guidelines, or failure to adequately monitor fume extraction exhaust air and the ambient workplace air for the presence of harmful levels of gases, fumes and particulates.

Compliance with all applicable environmental and personal safety regulations is the sole responsibility of the user. Adequate self-monitoring of exhaust air released into as well as monitoring of the ambient workplace air is strongly recommended. To insure continued effective performance, the following guidelines must be followed.

Dangers

1. PACE Fume Extractors are not intended to be used as a substitute for devices such as personal protective respirators which are designed to remove poorly adsorbed substances including carbon monoxide, methane, hydrogen, acetylene and other gases. Risk of serious injury or death, fire or explosion may result from improper use. If in doubt, contact your industrial hygienist or PACE.
2. Never use PACE Fume Extraction Systems to extract fumes from highly flammable liquids and gases such as Ether, Gasoline (Petrol) and others. Risk of serious injury, death, fire or explosion may result.
3. High concentrations or airborne contaminants such as Methyl Ethyl Ketone, Cyclohexane, Ozone and others when contacted with activated carbon, can undergo oxidation, decomposition or polymerization resulting in exothermic reactions or heat generation. PACE Fume Extraction Systems must not be used to extract fumes from these substances when high concentrations are present.
4. Failure to comply with the application and maintenance guidelines, filter replacement schedules, monitoring recommendations and safety guidelines contained herein and in other relevant product safety literature (i.e., Material Safety Data Sheets) provided with the substances and equipment producing the fumes to be extracted could result in risk of serious injury, fire or explosion.

Introduction

Solder Fume removal when hand soldering is an often-overlooked work place hazard. Medical research has confirmed an increased incidence of occupational asthma, chronic bronchitis, allergic reactions and other deleterious health effects to be associated with exposure to solder/flux fumes in the electronics industry.

The Arm-Evac 50 is a self-contained, compact and portable bench-top filtering fume removal system. The Arm-Evac 50 has Airflow Control and Filter Condition Monitoring to alert the operator when it is time to change the filter and incorporates a high performance 24vDC brush less motor for years of trouble free use without maintenance. The Arm-Evac 50 has been designed to take up a minimum of bench space and incorporates a utility platform to stack soldering irons and hand tools etc.

As standard, the Arm-Evac 50 operates as a Self Contained Plenum. The plenum type extraction provides fume removal for a wide capture area. Should the fume capture require a more localized extraction, the Arm-Evac 50 can be configured to offer Arm-Extraction via an optional accessory. The fumes are drawn from the point of origin through the Static-Safe system, filtered and returned to the work environment as clean air.

In addition to offering two types of fume collection from a single unit, the Arm-Evac 50 offers two choices of filtration, 1) A General Purpose Filter for normal Soldering applications. 2) A Clean room Filter for use in clean room environments.

Specifications

Arm-Evac 50 System Part Number	8889-0050
System voltage	120/230 VAC, 50/60Hz
Flow Rate	90cfm with std filter @ max motor speed
	45cfm with one Arm open
	30cfm with both Arms open
Noise Level	54.5dbA at 2 meters
Weight	6kg (13lbs)
Size H x W x D	250 x 330 x 315mm
	8.5" x 13" x 12.5"
Housing	Steel chassis with ABS shell (static safe)
Filter Monitoring	LED display

Features

Arm-Evac 50 Benchtop Plenum/Arm Extractor

- 1. Airflow Control Switch
- 2. Filter Condition Monitoring LED
- 3. Filter Access Cover
- 4. Power receptacle / On-Off Switch
- 5. Utility Platform
- 6. Arms & adaptor (optional)



Fig 1: Arm-Evac 50 Benchtop Plenum/Arm Extractor

Set up

1. The Arm-Evac 50 has been designed for ease of use and with maximum installation flexibility in mind. The major considerations for placement of the unit are:
 - **Exhaust Port:** This is located at the rear of the unit. When positioning the unit, make sure the exhaust port is not blocked or that airflow from the exhaust port is restricted.
 - **Proximity to work area:** The unit should be placed as close to the work area as possible. Do not create any sharp bends in the flexible Extraction Arms (optional), as this will reduce airflow.
2. The Arm-Evac 50 will plug into a standard 110v or 230v electrical outlet. A line cord is provided with each system.
3. The Arm-Evac 50 is fitted with a Filter Condition Monitoring LED. The LED will illuminate in the following manner: During normal operation, the LED will illuminate green. As the filters become clogged and the airflow rate decreases, the LED will turn to amber then finally to red when the filters are fully blocked. The Filters **MUST** be replaced when the LED illuminates red. (NOTE: When the Airflow Control Switch is set in its lowest position, the Green LED will flash to alert the user that the unit is in operation).
4. Before operating the unit, make sure the filters are correctly positioned. The pre-filter should always be positioned towards the front of the unit.



Fig 2. Arm-Evac 50 set up for Plenum Extraction (supplied as standard)



Fig 3. Arm-Evac 50 set up for optional Extraction Arms.

Plenum Operation

1. Remove Arm-Evac 50 from packaging and place on workbench.
2. Insert filter, ensuring that you follow airflow guide.
3. Plug power cord (supplied) into receptacle at rear of unit, ensuring that it is connected to a properly grounded outlet.
4. The unit is now ready for use.

Optional Arm Extraction Operation

1. Ensure Arm-Evac 50 is switched off and is disconnected from power outlet.
2. Lift Arm-Evac unit and slot the arm adaptor into the plenum opening.
3. Push fit extraction arms into outlets of the arm adaptor. If only one Extraction Arm is required, use the blanking plug supplied to block other outlet.
4. Position arms as required.
5. Follow steps 1, 2 & 3 of Plenum Operation
6. The unit is now ready for use.

Maintenance

Fuses: The fuse is located in a sliding tray at the rear of the unit, just below the power receptacle. Each Arm-Evac is supplied with one replacement fuse, also located in the sliding tray.

Fan Assy: The Arm-Evac 50 is fitted with a maintenance free, brush-less fan assembly. It is important that fume extractor filters are changed on a regular basis to protect the fan assembly.

Housing: The housing of the Arm-Evac 50 is manufactured from a static safe ABS material, which may collect a build up particulates and flux fume residue. We recommend the use of a mild, plastic safe cleaner with a soft cloth to clean the unit, should it be required.

A vent is located at the rear of the unit to allow the cleaned air to return to the workplace. Covering this vent may cause damage to the fan assembly.

Never operate the Arm-Evac 50 without filters installed.

Troubleshooting

Symptom	Possible Causes	Solution
System will not turn on.	No power supplied to unit	Make sure the power cord is fully seated and that the power is turned on.
Reduced Airflow	Filter blocked.	Check & change filter(s)
	Arm attachment not installed correctly.	Make sure all accessories are fully seated.

If the unit does not work after checking the above, please contact PACE, or your authorized PACE distributor.

Filter Replacement & Spare Parts

PACE fume extraction systems are equipped with filters designed to capture particulates and noxious gases and odors. Over time the filters will become clogged, impeding airflow through the system as well as reducing the ability of the gas filter (if present) to continue to neutralize and adsorb noxious gases and odors.

Do not attempt to clean any PACE fume extraction filters for reuse. Cleaning the filters will severely damage the filter media and negatively effect the filter's performance. This can result in unfiltered, contaminated air returning to the working environment or damaging the fan assembly.

To ensure the highest level of performance, use only PACE replacement filters in your PACE Fume Extraction System.

BE SURE the new filter cartridge is installed with the airflow arrow pointing away from the front of the unit.

When disposing of used filters, extreme care must be taken to comply with *all* applicable environmental regulations. Consult the MSDS supplied with the material(s) producing the fume. If in doubt, check with your local Environmental Authority.

<u>PART NUMBER</u>	<u>DESCRIPTION</u>
8889-0050-P1	ARM-EVAC 50 (DUAL VOLTAGE)
8883-0125-P5	ARM-EVAC 50 PRE-FILTER PKT 5
8883-0280-P1	ARM-EVAC 50 STANDARD FILTER (85%)
8883-0290-P1	ARM-EVAC 50 CLEAN ROOM FILTER (99%)
8886-0055-P1	ARM-EVAC 50 ARM ADAPTOR & ARMS (2)

Warranty

Seller warrants to the first user that products manufactured by it and supplied hereunder are free of defects in materials and workmanship for a period of three (3) years from the date of receipt by such user. This Warranty as applied to blowers and motor pumps is limited to a period of one (1) year. Monitors, computers and other brand equipment supplied by not manufactured by PACE are covered by their respective manufacturer's warranty in lieu of this Warranty.

This warranty does not cover wear and tear under normal use, repair or replacement required as a result of misuse, improper application, mishandling or improper storage. Consumable items such as tips, heaters, filters, etc. which wear out under normal use are excluded. Failure to perform recommended routine maintenance, alterations or repairs made other than in accordance with Seller's directions, or removal or alteration of identification markings in any way will void this warranty. This warranty is available only to the first user, but the exclusions and limitations herein apply to all persons and entities.

SELLER MAKES NO OTHER WARRANTY, EXPRESS OR IMPLIED, AND MAKES NO WARRANTY OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE.

Seller will, at its option, repair or replace any defective products at its facility or other location approved by it at no charge to user, or provide parts without charge for installation by the user in the field at user's expense and risk. User will be responsible for all costs of shipping equipment to Seller or other location for warranty service.

EXCEPT FOR THE REMEDY ABOVE DESCRIBED, UNLESS OTHERWISE REQUIRED BY APPLICABLE LAW, SELLER WILL HAVE NO OTHER OBLIGATION WITH REGARD TO ANY BREACH OF WARRANTY OR OTHER CLAIM WITH RESPECT TO THE PRODUCTS, OR LIABILITY FOR ANY DIRECT, INDIRECT, CONSEQUENTIAL, OR INCIDENTAL LOSS OR DAMAGE CAUSED BY OR OCCURRING IN CONNECTION WITH ANY OF THE PRODUCTS.

Warranty service may be obtained by contacting the appropriate PACE Company or local Authorized PACE distributor as set forth below to determine if return of any item is required, or if repairs can be made by the user in the field.

Defective products may not be returned to PACE without a Service Authorization ("SA") Number. Any warranty or other claim with respect to the products must be made in writing delivered to PACE (or local Authorized PACE distributor for Buyers outside the USA and the United Kingdom) within a reasonable time of the expiration date of this warranty with sufficient evidence of purchase and date of receipt, otherwise user's rights under this warranty shall be deemed waived.

Questions or comments? Contact us at:



PACE Incorporated
346 Grant Road
Vass, NC 28394

Tel: (877) 882-PACE
Tel: (910) 695-7223
Fax: (910) 695-1594

Pace Europe
11 Holdom Avenue
Bletchley, Milton Keynes,
United Kingdom, MK1 1QU

Tel: 011 44 1908 277666
Fax: 011 44 1908 277777

You can also visit us on the World Wide Web at <http://paceworldwide.com/>
or reach out to us by email at support@paceworldwide.com